IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13179 PIN# ~~4626-84-1668-785~~ 4626-19-1058 DATE 3/20/07

OWNER OR APPLICANT Jasper Builders PHONE: Business _____ Home _____

ADDRESS 804 N Main St Mooresville 28115

LOCATION Brawley School Rd, TR McKendree TR Bare Foot Ln, TR E Cold Hollow Farm on Left

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 485 LOT AREA 1.21 Acre SITE CLASS. P.S. DESIGN FLOW 600 L.T.A.R. .35

Septic Tank: 1500 Gallons: STB 309 Date 6/18/07

Pump Tank: 1500 Gallons: PT 333 Date 5/25/07

Pump Make: Ecoids Model PE5THH Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 24" 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☑ Pressure

☑ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: Low Pressure Panel

Repair System Description: Low Pressure Panel

Maintenance Agreement Required: ☐ Yes ☐ No

☐ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons ____

☐ Business No. Employees ____

☐ Other _____

Water Supply: ☐ Individual ☐ Public ☒ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

1) *4 Lines equaling 400' total on contour - Pressure dosed
2) Stay 5' off driveway
3) 10' off any R/W

Comments:/Conditions:

House & driveway installed encroaching on drainfield plus utilities R/W not to drain easement - Re-layout to 6 lines, LP Panel, as shown on

INITIAL SITE SKETCH

*57
66
72
75
67
63

Garage
Proposed Area
Site
Pond
Pt
St
DRIVEWAY
DRAIN EASEMENT
2/18/

AS BUILT SKETCH ~~Corrects~~ lengths stated*

Tanks Checked by JA 6/7/07
Lines Checked by MB 6/18/07

2/18 - Some Repair

*See "As Built" Attached

DRIVEWAY
Cold Hollow Rd

Permit can be suspended or revoked if any false information is supplied toward securing the permit, any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Terri Crawley date 3-21-07 Installed by: Richard Abernathy

Improvement Permit by: [signature] date 3/20/07 Operation Permit by: [signature] date 7/3/07

Authorization to Construct by: [signature] date 3/20/07 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK