DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6/3
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 485 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear 2-4%	0-2	Mo GR L	SS SP FR	DK Br				.25
		2-25	Mo SBK C	SS SP FR	Red; F Fm Yel Br Relic & quartz				
		25-52	WK SBK CL	SS SP FR	Red; C Yel Br Relic & Sap				
					FF quartz on top soil 12"+ & weathered rock				
2	Linear 4-6%	0-3	Mo GR L	SS SP FR	DK Br				.3
		3-24	Mo SBK C	SS SP FR	Red				
		24-39	Mo SBK CL	SS SP FR	Red; F F mica; Roots to 36"				
		39-48	WK SBK CL	SS SP FR	Red; C Sap; F Yel Br Relic				
3	Lot 486 Pit 1 Linear 2-4%	0-1	Mo GR L	SS SP FR	Dk Br				.3
		1-25	Mo SBK C	SS SP FR	Red; F Relic Yel Br				
		25-52	WK SBK CL	SS SP FR	Red; F mica; F/C Sap				
4	9-15-05	0-6	WEAK Blocky Subangular	Friable Loamy Sand					.25
		6-27	SBK RC	FRIABLE SS SP SAND					
		27-49	WEAK RC	FRIABLE SS SP SAND with gravel					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____

(OVER)