Statesville Analytical, Inc.
122 Court Street; PO Box 228; Statesville, NC 28687
Phone (704) 872-4697, www.sa-nc.com

Client Name:(usually buyer) Bruce-Sara Colmark

Address (where sample taken) 572 Lakeview Shores Ln. Mooresville NC 28115

Location of Sample Taken Well. (kitchen, bath, outside, etc.)

Sampling Time 12 : 20 P M **Sampling Date** 07 / 24 / 2023

Person collecting sample B. Janvrin

Parameters requested for analysis: *Please check tests needed*:

[X] Total Coliform Bacteria [ ] Lead [X] Nitrate [X] Nitrite

Other ~~NON~~

Mail Results to:
Tim Whelan Homes
748 Brawley School Rd. Mooresville NC 28117

Phone: (704) 400-8932 **Email:** timwhelan@whelanhomes.net

LABORATORY ID #37755

CONTAMINANT	METHOD CODE	RESULTS PRESENT[1,2]	RESULTS ABSENT	INVALID CODE
Total Coliform	9223B		✓	
Fecal/E. coli	9223B		✓	

	DATE: (MM/DD/YY)	TIME: (Specify AM or PM)
ANALYSES BEGUN:	07/24/23	15:30 P M
ANALYSES COMPLETED:	07/25/23	09:30 A M

Laboratory Log #: 230724.10.01 **Certified By:** W. COOK

Comments:

Analytical Results

STATESVILLE ANALYTICAL

T.Whelan Homes

748 Brawley School Rd
Mooresville, NC 28117

Receive Date: 07/24/2023

Reported: 07/26/2023

For: 572 Lakeview Shores Loop Mooresville NC 28115

Comments: Acceptable limits for drinking water are:

Total Coliform = Absent, E.Coli = Absent, Lead <0.015 mg/L, Nitrate <10.0 mg/L, Nitrite <1.0 mg/L

Sample Number	Parameter	Sample ID	Result	Unit	Method	Analyzed	Analyst
230724-10-01	E. Coli	Colmark	Absent		9223B	07/24/2023	WC
230724-10-01	Nitrate	Colmark	<1	mg/L	353.2	07/26/2023	CL
230724-10-01	Nitrite	Colmark	<0.1	mg/L	353.2	07/26/2023	CL
230724-10-01	Total Coliforms	Colmark	Absent		9223B	07/24/2023	WC

Respectfully submitted,

Melissa A. Myers

Melissa Myers
NC Cert #440,
NCDW Cert #37755,
EPA #NC00909