DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 4/3
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 487 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear 2-4%	0-3	Mo GR SL	SS SP FR	Br				.25-.3
		3-32	WK ABK C	SS SP FR	Red				
		32-52	WK SBK CL	SS SP FR	Red Yel; C sap; F Yel Br Relic				
					Back wall 18-24" quartz vein				
2	Linear 4-6%	0-3	Mo GR L	SS SP FR	DK Br				.25-.3
		3-37	Mo SBK C	SS SP FR	Red; F Rocks; F/C WR Yel Br		F/C Weathered Rock Yel Br & White		
		37-52	WK SBK CL	SS SP FR	Red; F/C WR Yel Br F,F sap				
A/B	10% L	0-5	WK SBK reddish sdl	fr (dry) SS SP					.3
		5-18	SBK RC	fr SS SP SBK					
B/4		0-5	WK SBK reddish sdl	fr SS SP					.25-.3
		5-31	SBK RC	fr SS SP SBK					
		31-50	WK SBK yr CL	fr SS SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____