IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

375

PERMIT# 13280 20089 PIN# 4626 07 1628.488 4626196098 DATE Sept 20, 05

OWNER OR CONTRACTOR The Farms, LLC HARRIS CONSTRUCTION PHONE: Business _____ Home _____

ADDRESS 3214 Brawley School Rd, Mooresville, N.C. 28117

LOCATION Brawley School Rd TR McKendree TR BARE FOOT LANE TR East Cold Hollow Farms Dr. 5th Lot on left

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 488/488A LOT AREA .736Ac + .351Ac SFE SITE CLASS 5 SFE DESIGN FLOW 480gpd L.T.A.R. @ 3 SFE 488A

Septic Tank: ~~1000~~ + 1500 Gallons; STB 390 Date 5-5-14

Pump Tank: 1000 Gallons; PT 363 Date 5-27-14

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 536/804 Linear Feet 268

No Lines 4 Trench Width 24"min 30" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: LPPPBPS on SFE 535-488A

Repair System Description: SAME

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☐ Other _____

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: Dr = 36" max 96c

Partial site evaluation and system design performed by Paul Pennington and Kathleen Hanes w/ SME

Comments:/Conditions: 7/17/14 Checked tanks & lines

INITIAL SITE SKETCH

SEE Plan from SME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plan valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 9-28-05

Improvement Permit by: _____ date 9-20-05

Authorization to Construct by: _____ date 10/28/13

Installed by: Custer Grading

Operation Permit by: _____ date 3-24-14

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK