IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Paid MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13/330 PIN# ~~4626 07 1628.504~~ 4626198913 DATE Sept 27, 05

OWNER OR CONTRACTOR The Farms LLC / ES Johnson PHONE: Business (704) 660-1185 Home

ADDRESS 2314 Brawley Sch Rd. Mooresville N.C. 28117

LOCATION Brawley Sch Rd. TR McKendree TR Lakeview Shores Loop TL Athol TR Willow Bend Ct. 2nd lot on left

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 504 LOT AREA 1.154 Ac SITE CLASS. PS DESIGN FLOW 440 gpd L.T.A.R. .025

Septic Tank: 1000+ Gallons; STB 444 Date 9-8-07
Pump Tank: 1000 Gallons; PT 27 Date 8-19-07
Pump Make: Myers Model ME50526 Serial No.
Nitrification Field: No Fields 1 Square Feet 640/960 Linear Feet 320
No Lines 2 (CF) Trench Width 24" min 48" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: LPP PBPS
Repair System Description: LPP PBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Bathrooms
☐ Business No. Employees
☐ Other
☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: @ 36" MAX 96c

Initial site evaluation and system design performed by Paul Pennington and Kathleen Hoover, S&ME

Comments:/Conditions: Installed in 4 Panel lines
11/1/07 Checked tanks & lines

INITIAL SITE SKETCH

SEE Plan from S&ME

AS BUILT SKETCH

Installed essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kathleen Hoover date 9/30/05 Installed by: Willie Christenbury

Improvement Permit by: date 9-27-05 Operation Permit by: Maria Hall Dotson date 11/2/07

Authorization to Construct by: Wesley Spencer date 11/1/07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK