DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 4/30
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 490 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear 0-2%	0-16	WK SBK L	SS SP FR	Br				.25
		16-38	MO SBK SCL	SS SP FR	Red Br				
		38-52	WK ABK CL	SS SP FR	Red; few	yellow br	½ red mottles in root channels		
2	Linear 0-2%	0-10	WK SBK SL	SS SP FR	Br				.75
		10-30	MO SBK SCL	SS SP FR	Red Br; few Mn concretions				
		30-49	MO SBK/WK MPL	SS SP FR	Red; F yellow br, pale br mottles				
A B	2% ± L	0-7	gr-WK SBK brn sl-L fr-fr sss sp ss sp						.3
		7-50	SBK rd cl L	fr-fr sss sp ss sp	(very dry soil)				
B 4		0-41	WK SBK brn sl cl L	fr sss p					.3
		41-51	WK MSBK c/cl	fr sss p ss p	(very dry)				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____