IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR [redacted] DATE 3-27-75 PERMIT NO. 49

PHONE: Business 827-2231 Home Wade FOX

LOCATION 1100 Tkw 1172 1/2 mi TL on 1459, 1/4 mi on Left S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 158 SECTION OR BLOCK NO. 2

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1/4 acre


Character & Porosity of Soil Fine Sandy Clay loam

Percolation Rate Not taken

Topography 2% to 3% Slope

Depth to Water Table 6 to 8'

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by C M Sherrill + Son

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 3-27-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold