IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eugene S Adams DATE 6-12-22 PERMIT NO. _____

PHONE: Business 568-2128 Home _____

LOCATION 1100 feet Pow 1173 2 Pow 1238 ½ mi on Left S. R. No. 7

SUBDIVISION NAME Lake Norman LOT NO. 43 SECTION OR BLOCK NO. 7


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay Loam Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	20 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Soft Earings
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	22 & Steep
			Rock or other impervious formations	10' Some Subsurface Rock

Lot Area ½ acre

Lake



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250'
Depth of Stone in Lines 20"

Water Supply: Individual (✓)
Public ( )

Installed by Slagle
Winchester
Septic Tank
Contractor
Charlotte

IMPROVEMENTS PERMIT BY Robert Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Robert Houston DATE 6-17-22

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold