9412

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Elijah J. Tyson DATE 1/13/89 Quad: PERMIT NO. 20 B

PHONE: Business _____ Home 537-2590

LOCATION 1100 TR McKendrie TL 2nd Kemp ~4 mi on R.

S. R. No. _____

SUBDIVISION NAME Crescent Land & Timber LOT NO. 153 SECTION OR BLOCK NO. 1631-Grand F

Davidson : ZF-3-A-153

?future Present House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clay
Percolation Rate .35 gpd/ft²
Topography 60%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area 1.08 A

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Elijah J. Tyson

IMPROVEMENTS PERMIT BY Andre C. Pierce

COMMENTS: System must be installed at a Lake Shallow depth and on Contour. Ditches must be 24"- 30" maximum depth. Install tank and drain lines to accommodate a future house

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold