DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ *of* ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: 326 Farms III PROPERTY RECORDED: _____
WATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other _____
EVALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut
TYPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10	BSCL WSM	fri SSSL					PS .3
		10-27	RC ABK	fri SP					
		27-54	RCL MSBK	fri SSSP					
2	TJ+As.	0-9	L GR	fri SSSP					PS .3
		9-44	RC SBK	fri SSSP					
3		0-20	BSCL WSM	fri SSSP	Few Mn concretions 39"+ to ~ chroma				PS .25
		20-58	RC ABK	fri SS,P					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____

8"PVC
INV=792.21
8"PVC
INV=791.87
8.58
140'
15"RCP
INV=789.64
68'
241'
800
805
810
329
1.02 Ac.
328
0.82 Ac.
327
0.78 Ac.
313'
259'
15A'
222'
253'
83.15'
SETBACK
57.28'
SETBACK
59.40'
SETBACK
78.2
DRIVE
ALDER
50'
64'
10+45.78
10+00
43'