202487 400

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # ~~H96536~~

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4626 28 9806

APPLICANT: William Walsh APPLICANT ADDRESS: 189 Bayberry Creek Circle Mooresville 28117

SITE ADDRESS: 189 Bayberry Creek Circle Mooresville PHONE: 704-929-5357 ALT. PHONE:

SITE DIRECTIONS: Brawley School Rd TR McKendree TL Bayberry Creek Circle on Left

SUBDIVISION: The Farms SECTION: 3 LOT # 433 LOT AREA: .96 Ac DESIGN FLOW: 480 gpd L.T.A.R.: .275 gpd/ft²

Septic Tank Existing (gal) STB Date
Pump Tank Existing (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 4 Linear Ft: 430
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: 2590 Reduction pm
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ YES ☒ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons
☒ Other Pool No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions: Existing House. System relocated for addition of pool. Pool shall be min. 15' from septic tanks and drainfield. Properly abandon existing drainfield.

INITIAL SITE SKETCH

See Plan from SAME

Approved by ICHD

AS BUILT SKETCH

1/2 1180 TAPS

OLD LINES CUT OFF

27CM/DITCH

INSTALLED AS SHOWN ON PLAN

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: W Walsh Date: 3-28-14 Installed by: RANDY MELTON

IMPROVEMENT PERMIT by: Andy Melville REHS Date: 3-27-14 OPERATION PERMIT by: BA 005 APPROVED MAY 14 2014 Date:

AUTHORIZATION TO CONSTRUCT by: Andy Melville REHS Date: 3-27-14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK