IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 / 130.00 Paid MOORESVILLE 704-664-5281

10.15

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 131301 PIN# 4626 07 18 28.492 4626291479

OWNER OR CONTRACTOR The Farms LLC / TESTA HOMES PHONE: Business DATE Sept 27,05

ADDRESS 224 Brawley School Rd, Mooresville, N.C. 28117 Home

LOCATION Brawley School Rd. TR McKendree TR BARE Fwd Lt. TR Eastfield Hollow Farms Dr. at end

SUBDIVISION The FARMS BLOCK / SECTION 4 LOT 492 LOT AREA 1.09ac SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .03

Septic Tank: 1600gal Gallons: STB ~~1250~~ 1338 Date 7-27-07

Pump Tank: 1000 Gallons: PT 283 Date 2-26-07

Pump Make: Goulds Model WFE0512M1 Serial No.

Nitrification Field: No Fields 1 Square Feet 200 Linear Feet 400

No Lines 4@100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: pm 25% Reduction

Repair System Description: LPPBDS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms No. Employees

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments/Conditions: 9/19/07 Set 3ft pressure

Initial site evaluation and system design performed by Paul Hendricks and Kathleen Hawes of S&ME

INITIAL SITE SKETCH

SEE Plan from S&ME

Comments/Conditions: Installed Quick 4" Infiltrators for Drainfield

9/19/07 Checked tanks, lines & pressure

AS BUILT SKETCH

Electrical & Floats Checked 11/27/07 AC

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kathleen Hawes

Improvement Permit by: date 9/30/05

Authorization to Construct by: date 9-27-05 / 3/28/07

Installed by: C. Wayne Orbison

Operation Permit by: Anthony Eden date 11/29/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK