IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 131439 PIN# 4626 07 1828.570 4626-29-1856 DATE Sept 28, 05

OWNER OR CONTRACTOR The Farms LLC / Craig Carter PHONE: Business _____ Home _____

ADDRESS 2214 Brawley Sch Rd, Mooresville N.C. 28117

LOCATION Brawley Sch Rd TR McKendree TR Lakeview Shores Loop TR Abbot TR Willow Bend Ct. 1st Lot on Right

SUBDIVISION The FARMS BLOCK / SECTION 4 LOT 510 LOT AREA .822Ac+.110Ac SITE CLASS. 15 DESIGN FLOW 480gpd L.T.A.R. .03

Septic Tank: 1000+ Gallons; STB 338 Date 5-26-07

Pump Tank: 1000 Gallons; PT 283 Date 6-26-07

Pump Make: Goulds Model WE03/2M Serial No Sld 1517064

Nitrification Field: No Fields 1 Square Feet 534/801 Linear Feet 267

No Lines 4 Trench Width 24"min 36"max Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☐ Other ____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: 36" max 90c

Initial site evaluation and system design performed by Paul Swango and Kathleen Haver of S&ME

Comments:/Conditions: 8/16/07 Checked tanks, lines & pressure.

INITIAL SITE SKETCH

SEE Plan from S&ME

AS BUILT SKETCH

Installed essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kathleen Haver date 9/30/05 Installed by: Richard Abernathy

Improvement Permit by: _____ date 9-28-05 Operation Permit by: Wesley Sparks R.S. date 10/5/07

Authorization to Construct by: Wesley Sparks R.S. date 2/19/09 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK