DIVISION OF ENVIRONMENTAL HEALTH
ON SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRI — APPLICANT:
ADDRESS: — APPLICATION DATE: — DATE EVALUATED: 5-28
PROPOSED FACILITY: — PROPOSED DESIGN FLOW (.1949): — PROPERTY SIZE:
LOCATION OF SITE: Hastow phase 3 — PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☒ Public / ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L ~6-8%	0-2	9 Okn SL	fr					
		2-46	SBK RCL	fi-vfi ss,sp	1:1				.3
2	L ~8%	0-6	SBK RCL						
		6-31	SBK RC	fi sp 1:1					.3
		31-48	wksbk loamy RCL						
3	L 6-8%	0-6	scL/SL	fr					
		6-42	sbk RC	fi sp 1:1					.3
4		0-8	gran/scL	fr					
		8-48	SBK RC	fi sp 1:1					.3
			few 4 cm mottles						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: