4626318687

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Williams DATE 6-28-79 PERMIT NO. 225

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1177 ½ mi. on Rt. _____

_____ S. R. No. _____


SUBDIVISION NAME Holiday Harbor LOT NO. 89 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 133'X 143'

Character & Porosity of Soil clay loam
Percolation Rate 30 mpi
Topography 2%
Depth to Water Table unk.
Rock or other impervious formations none obs



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Hunter

COMMENTS: Layout changed w/out notifying Health Dept. Well put in front so system had to be put in as sketched above.

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 6-28-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold