DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mid Atlantic Custom Bill Bethune
ADDRESS: ___
PROPOSED FACILITY: Residential PROPOSED DESIGN FLOW (.1949): ___ APPLICATION DATE ___
LOCATION OF SITE: Brawley Sch Rd TR Chuckwood TR Indian Tr Lot 24 DATE EVALUATED: 9-15-05
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other PROPERTY SIZE: .99 PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4%D middle	0-6	1sbk cl			48			PS .3
		6-36	2 abk c	fr ss/sps e					
		36-52	1 sbk/abk c+sap						
2	1st facing back 3rd	0-6	1sbk scl	ss/sps e					.3
		6-24	2 abk cl	ss/sps e					
		24-50	1 abk c/+sap	+ incl. quartz rock					
3	rt	0-4	1sbk. scl						PS .3
		4-32	2 abk/sbk cl						
		32-55	1 abk cl+sap						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)	yes	yes
tem Type(s)	25% gravity	LP Panel
LTAR		

MENTS: ___

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Judy Melville
OTHER(S) PRESENT: ___