WELL ABANDONMENT RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2020

1. WELL CONTRACTOR:
Jason Steele
Well Contractor (Individual) Name
Steele Well Co. Inc.
Well Contractor Company Name
STREET ADDRESS 335 Hill Haven Dr.
Cleveland NC 27013
City or Town State Zip Code
(704) 278-4849
Area code - Phone number

2. WELL INFORMATION:
SITE WELL ID # (if applicable)
STATE WELL PERMIT # (if applicable)
COUNTY WELL PERMIT # (if applicable)
DWQ or OTHER PERMIT # (if applicable)
WELL USE (Check applicable use): ☐ Monitoring ☒ Residential
☐ Municipal/Public ☐ Industrial/Commercial ☐ Agricultural
☐ Recovery ☐ Injection ☐ Irrigation
☐ Other (list use)

3. WELL LOCATION:
COUNTY Iredell QUADRANGLE NAME
NEAREST TOWN: Mooresville
Aquarius Ln
(Street/Road Name, Number, Community, Subdivision, Lot No., Parcel, Zip Code)
TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(Check appropriate setting)
LATITUDE
LONGITUDE
May be in degrees, minutes, seconds, or in a decimal format
Latitude/longitude source: ☐ GPS ☐ Topographic map
(Location of well must be shown on a USGS topo map and attached to this form if not using GPS.)

4a. FACILITY- The name of the business where the well is located. Complete 4a and 4b. (If a residential well, skip 4a; complete 4b, well owner information only.)
FACILITY ID #(if applicable)
NAME OF FACILITY:
STREET ADDRESS
City or Town State Zip Code

4b. CONTACT PERSON/WELL OWNER:
NAME Spivey Construction
STREET ADDRESS PO Box 4268
Mooresville, NC 28117

5. WELL DETAILS:
a. Total Depth: 192 ft. Diameter 6 in.
b. Water Level (Below Measuring Point): ft.
Measuring point is ft. above land surface.

6. CASING: Length Diameter
a. Casing Depth (if known): ft. in.
b. Casing Removed: 0 ft. in.

7. DISINFECTION: HTH
(Amount of 65%-75% calcium hypochlorite used)

8. SEALING MATERIAL:
Neat Cement 4171 lbs Sand Cement
Cement 43 bags x 94 lb. Cement lb.
Water 172 gal. Water gal.
Bentonite
Bentonite lb.
Type: ☐ Slurry ☐ Pellets
Water gal.
Other
Type material
Amount

9. EXPLAIN METHOD OF EMPLACEMENT OF MATERIAL:
Pump

10. WELL DIAGRAM: Draw a detailed sketch of the well on the back of this form showing total depth, depth and diameter of screens (if any) remaining in the well, gravel interval, intervals of casing perforations, and depths and types of fill materials used.

11. DATE WELL ABANDONED 6/27/08

I DO HEREBY CERTIFY THAT THIS WELL WAS ABANDONED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

SIGNATURE OF CERTIFIED WELL CONTRACTOR — DATE 6/27/08

SIGNATURE OF PRIVATE WELL OWNER ABANDONING THE WELL — DATE
(This private well owner must be an individual who personally abandons his/her residential well in accordance with 15A NCAC 2C .0113.)

PRINTED NAME OF PERSON ABANDONING THE WELL

Submit a copy to the owner and the original to the Division of Water Quality within 30 days.
Attn: Information Management, 1617 Mail Service Center – Raleigh, NC 27699-1617. Phone No. (919) 733-7015 ext 568.

Form GW-30
Rev. 5/06