323 Indian Trail

IREDELL COUNTY HEALTH DEPARTMENT 4626-33-6109

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR T.J. Kraft DATE 12-6-78 PERMIT NO. 291

PHONE: Business _____ Home 365-3622

LOCATION 1100 TR on 1177 TR on 1238 Near end on Left S. R. No. _____


SUBDIVISION NAME Lake Norman (CL&T) LOT NO. 22 SECTION OR BLOCK NO. 7

House ( ) Mobile Home (✓) Business ( ) Other _____ Area for Drain Field

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min/in	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	10 to 15% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10 ft	
			Rock or other impervious formations	Significant Rock	

Lot Area .68 ac + .32ac



Plot of System

Size of Tank 1000 + ½ of 1000 Gals Pump Tank

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by T.J. Erwin

IMPROVEMENTS PERMIT BY _____

COMMENTS: Rock on Lot had to Pump to area 1 Lot over.

CERTIFICATE OF COMPLETION BY John Houston DATE 12-6-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold