4626351264

IREDELL COUNTY HEALTH DEPARTMENT

12013

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Clyde Christenbury DATE 9/24/90 PERMIT NO. 2F-3-A-110

PHONE: Business _____ Home _____

LOCATION 1100 TL 1445 TL 1446 on right

S. R. No. _____


SUBDIVISION NAME CL+T LOT NO. 110 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other Existing See permit issued 10/25/77 Clyde M. Christenbury

No. Bedrooms 2	No. Bathrooms 2			Character & Porosity of Soil	
Garbage Disposal Unit	Yes ( )	No (✓)		Percolation Rate	
Auto. Dishwasher	Yes (✓)	No ( )		Topography	
Auto. Wash. Machine	Yes (✓)	No ( )		Depth to Water Table	
Site Suitable	Yes ( )	No ( )		Rock or other impervious formations	

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 17"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Jerry Barnette

IMPROVEMENTS PERMIT BY Sam Ingram EHS

COMMENTS: Adding 1 Bdr., 1 Great room, Screened porch, deck
Deck must be 5' off existing drainfield

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Sam Ingram EHS DATE 9/24/90

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold