IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Clyde Christenbury DATE 11-15-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1115 Then TL on 1445 Turn 2nd Rd to left 1st lot on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 110 SECTION OR BLOCK NO. 8

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre


Character & Porosity of Soil Fine Sandy Clay loam + Clay

Percolation Rate 60 min+

Topography 2-5% Slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 17"+

Water Supply: Individual (✓)
Public ( )

Installed by J.R. Bowles

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 11-15-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold