IREDELL COUNTY HEALTH DEPARTMENT

Statesville Phone TR 3-7271 Mooresville Phone NO 3-1271

PERMIT TO INSTALL SEPTIC TANK

Permit No. 84 Permit Date 5-22-1972

Owner Youngblood Address Charlotte

Installed By orbison Address Mooresville


Location of Property on Rt 1445 Sec 8 Lot 89

Tank		Capacity		Length of Lines		Fixtures	
Block	( )	1000	( )	225'	( )	No. of Baths	(2)
Precast	(✓)	1250	( )	250'	(✓)	Dishwasher	(not)
		1500	( )	Other		Garbage Grdr.	(not)
		Other				Other	

NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED.

Final Inspection 5-22-1972 Approved ( ) Disapproved ( )

Remarks well + house not located yet. lines + ~~T~~ are in a position to where when house is built there is going to be a lot of Traffic over them.



Sketch of Installation

J. C. Moore
Sanitarian