IREDELL COUNTY HEALTH DEPARTMENT STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # ~~H9474~~ 17649 PIN # 4626 36 5121 DATE 8/22/12

OWNER or APPLICANT MI HOMES PHONE: Business Home:

OWNER or APPLICANT ADDRESS

LOCATION / DIRECTIONS BRAWLEY SCHOOL RD - TR MCKENDREE - TL 1ST KEMP - ON RT

SUBDIVISION THE FARMS BLOCK / SECTION LOT # 375 LOT AREA DESIGN FLOW 600 L.T.A.R. .36 PO/FI

Septic Tank 1500 Gallons: STB 338 Date 3-19-13 ☑ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

Pump Tank Gallons: P T Date System Description: GRAVITY 35% REDUCTION

Pump Make Model Serial # Repair System Description: LP PPBPS

Nitrification Field No Fields 1 No Lines 7 Linear Feet 504 Maintenance Agreement Required ☐ YES ☒ NO

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A ☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 5 / 10 Water Supply

☐ Business No. Persons ☐ Private

☐ Other No. Employees ☐ Public

☐ Slab ☑ Crawl Space ☑ Community

☐ Basement w/plumbing ☐ Basement w/o plumbing

Comments / Conditions PLUMBING TO BE STUBBED OUT HIGH IN BACK TO ACHIEVE GRAVITY. IF PLUMBING IS TOO DEEP A PUMP WILL BE REQUIRED. (36" TRENCH BOTTOM)

Comments / Conditions

INITIAL SITE SKETCH

SEE MICHAEL ATHANAS & ASSOCIATES DESIGN.

AS BUILT SKETCH

ADS 36 Installed as Shown on plan. serial distribution

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 8/24/12 Installed by: Richard Abernathy RS

Improvement Permit by: Date 8/22/12 Operation Permit by: Date: 4/23/13

Authorization to Construct by: Date 8/24/12 Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant