House Corner: 5.2, Back Right Corner

Comments: Currently Lot 375 is permitted for a four bedroom septic system; the current owners wish to alter the current house location, add a fifth bedroom and a pool. The site is permitted with a .3 LTAR for both the initial and the repair, four additional soil observations were completed and all verified current rating of .3g/d/ft2. Please note the new proposed septic area is in the same location as the current permit. This is a crawl only/no basement and do not cut pad.