IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138982 PIN# ~~4627-63-6599~~ 4626-36-6956 DATE 11-20-06

OWNER OR APPLICANT The Farms LLC PHONE: Business 704-996-6330 (S&ME) Home or 704-942-1250 (S&ME)

ADDRESS 160 Wagner St Troutman NC 28166

LOCATION Brawley School Rd TR McKendree TL Kemp TR Alder Spring TL Bayberry on left

SUBDIVISION The Farms BLOCK / SECTION Ph 3 LOT 381 LOT AREA .778 Ac SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .3 gpd /ft²

Septic Tank: ~~1000~~ 500 Gallons; STB 338 Date 6/14/07

Pump Tank: 1000 Gallons; PT 283 Date 6/12/07

Pump Make: Gould's Model WPE0-3121 Serial No.

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 270

No Lines 3 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons 8

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☐ Public ☒ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Before AC issued 2 wells properly abandoned with documentation submitted to Health Dept.

System installed as per specifications of S&ME,

Comments/Conditions: 5/32" holes

INITIAL SITE SKETCH

Paul Penninger and Kathleen Saunders

5-9

5-9

6

6-7

6-6

6-9

AS BUILT SKETCH

25'-0"

4'-0"

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 11-29-06 Installed by: Richard Lebergmeier

Improvement Permit by: Judy McBride date 11-20-06 Operation Permit by: Wesley Hicks R.S. date 10/16/07

Authorization to Construct by: [signature] date 12-13-06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK