DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms Lot 381 APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: _____
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1948 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1942 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	L	0-12	Mo SBK C	FR SS/SP	Red				0.25
		12-18	Mo SBK CL	FR SS/SP	Red Br; F F Mn				
		18-42	WK SBK CL	FR SS/SP	Red Br;	F Mn			
		42-48	WK SBK CL	FR SS/SP	Red				
2	L	0-18	Mo SBK CL	FR SS/SP	Red		F sap		0.3
		18-30	WK SBK CL	FR SS/SP	Red		C/M sap		
		30-48	MA SK/L SAP	FR SS/SP	Red				
		11-21-06							
		Pit to eval. sap. & w 1/4 pit rock from w 30-40" otherwise L sap to 60" qm							
3	L	0-28	Mo SBK C	FR SS/SP	Red		F sap		0.3
		28-48	WK SBK CL	FR SS/SP	Red		C sap		
						28"-34"	F Relic Yel Br		
4	L	0-4	Mo GR SL	FR SS/SP	Br				0.3
		4-24	Mo SBK C	FR SS/SP	Red		F sap		
		24-45	WK SBK CL	FR SS/SP	Red		C sap		

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____