SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

ER: Lee (Easter) APPLICANT: Same
DRESS: APPLICATION DATE: DATE EVALUATED: 6/26/00
POSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
CATION OF SITE: lot 12 BB Creek Rd PROPERTY RECORDED:
TER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
ALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
PE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-22	RC SiL	FR SP					A, 3
	22-56	RCL vfSiL	FR SSSP					
	56-67	C SAP/wd Rock	FRSSSP					
	0-24	RC SiL	FR SP					A, 3
	24-48	RCL MSiL	FR SSP	Many SAP	Many Encountered			
	48-65	RCL MSiL	FR SSP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)		
em Type(s)		
LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: CBF
OTHER(S) PRESENT:

use the following standard abbreviations.

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR	LPP .1957 LTAR	MINERALOGY/ CONSISTENCE	STRUCTURE
C (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	NEXP (Non-expansive)	G (Single Grain)
V (Convex Slope)		LS (Loamy Sand)			SEXP (Slightly Expansive)	M (Massive)
) (Drainage Way)					EXP (Expansive)	CR (Crumb)
S (Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		GR (Granular)
P (Flood Plain)		L (Loam)				SBK (Subangular Blc
S (Foot Slope)						ABK (Angular Block
(Head Slope)	III	SI (Silt)	0.6 - 0.3	0.3 - 0.15		PL (Platy)
(Linear Slope)		SICL (Silty Clay Loam)				PR (Prismatic)
(Nose Slope)		CL (Clay Loam)				
(Ridge)		SCL (Sandy Clay Loam)				
Shoulder Slope)		SLC (Silt Loam Clay)			MOIST	WET
Terrace)	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	VFR (Very Friable)	NS (Non-sticky)
		SIC (Silty Clay)			FR (Friable)	SS (Slightly Sticky)
					FI (Firm)	S (Sticky)
		O (Organic)	None		VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
					EFI (Extremely Firm)	NP (Non-plastic)
						SP (Slightly Plastic)
						P (Plastic)
						VP (Very Plastic)

Wayne
363-0292

TES
RIZON DEPTH — In inches below natural soil surface
PTH OF FILL — In inches from land surface
TRUCTIVE HORIZON — Thickness and depth from land surface
ROUTE — S(suitable) or U(unsuitable)
L WETNESS — Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designatic
SSIFICATION — S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

uation of saprolite shall be by pits.
-term Acceptance Rate (LTAR): gal/day/ft²

Show profile locations and other site features (dimensions, reference or benchmark, and North).

