SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Lee Ender APPLICANT: Lamm
ADDRESS: APPLICATION DATE: DATE EVALUATED: 10/26/00
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
LOCATION OF SITE: Lot 13 BB Creek PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-18	RL SBK	FR SP	Common SAP				PS .35 .4
	18-32	VFRCL MASBK	FRM SSSP					
	32-64	L SAP M	FAF MSNP					
	0-22	RC SBK	FR SP	Many SAP				PS .3- .35
	22-36	CL WSBK	FAF SSP					
	36-72	SC SAP	WSBK FAF SSSP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: CBR
OTHER(S) PRESENT: