IREDELL COUNTY HEALTH DEPARTMENT 4626414692

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. Philip McGuire DATE 9-15-80 PERMIT NO. 287

PHONE: Business _____ Home _____

LOCATION 1100 TR 1177 about 0.3 mile on R

SUBDIVISION NAME Holiday Harbor LOT NO. 84 SECTION OR BLOCK NO. _____ S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes	(X)	No	( )	
Auto. Dishwasher	Yes	( )	No	(X)	
Auto. Wash. Machine	Yes	(X)	No	( )	
Site Suitable	Yes	(X)	No	( )	

Lot Area 20,000 ff²

Character & Porosity of Soil Clay loam
Percolation Rate ~~Satisfactory~~ 9
Topography Gently rolling
Depth to Water Table Unknown 3/0
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )

Installed by J. J. Ervin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY JHL

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 9-15-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold