IREDELL COUNTY HEALTH DEPARTMENT Coast Auth. STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

200

IMPROVEMENT PERMIT / ~~CERTIFICATE OF COMPLETION~~ / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 23357 DATE August 12, '97 TAX MAP NO. part of 2CA3 Watershed: ☑ Yes ☐ No

OWNER OR CONTRACTOR ~~Crescent Resources Inc~~ Sally Burbank PHONE: Business _____ Home _____

ADDRESS PO Box 1003, Charlotte

LOCATION Brawley Sch Rd: TR Chuckwood TL Morrow's Ridge immediately on Right

SUBDIVISION The Harbours BLOCK / SECTION 3 LOT 8 LOT AREA 1.5 AC SITE CLASS. RS 1 DESIGN FLOW 360gpd L.T.A.R. ~.12

Septic Tank: 1000 Gallons; STB 794 Date 12/23/96

Pump Tank: 1000 Gallons; PT 27 Date 2/14/97

Pump Make: NORMATIC Model SHEF 50 Serial No. _____

Nitrification Field: No Fields 3 Square Feet 3000 Linear Feet 606

No Lines 7 Trench Width 18" Max Trench Bottom Depth 12" Gravel Depth ~8"

☑ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LPP

Repair System Description: LPP Pavel/Back on BA

Maintenance Agreement Required: ☑ Yes ☐ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 3

☐ Business No. Employees _____

☐ Other _____

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Community ☐ Public

Comments:

Comments: 6/25/99 - FAXED TO TRI COUNTY Waste Water - WS.

INITIAL SITE SKETCH

SEE LPP plan by TC Jacobs & Assoc.

AS BUILT SKETCH

system malfunctioned. see repair permit for new system installed off site.

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Issued by: Tracy Griffith, CPSS (agent) date 8/18/97

Permit by: _____ date 8-18-97

Inspection by: Wesley Sparks RS. date 8/17/98

Installed by: McLeod

Certificate of Completion by: _____ date _____

Operation Permit by: _____ RS date 4/5/99

WHITE COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD