IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

15274

DATE Nov. 30 '92 PERMIT NO. 2F-6A-71

OWNER OR CONTRACTOR Michael D. Skipper

PHONE: Business _____ Home _____

LOCATION 1100 TR 1177 (Chunkwood) TR Seagrove TR Lakeland ~300' on left

S.R. No. _____

SUBDIVISION NAME Holiday Harbor LOT NO. 71 SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~20,000 ft²

Soil Characteristics very shallow ps clay

Application Rate .3 at 19" trench bottom

Topography ~4%

Depth to Water Table 30"+

Rock or other impervious formations 30"+

☐ Basement with Plumbing ☐ Basement without Plumbing ☑ No Basement ☐ Crawl Space

Size of Tank 1000 ST / 1000 PT Gals.


Nitrification Field:

No. of Lines ~4

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐



Plot of System (Not to Scale)

Installed by _____

I understand and agree to install a septic tank syste as specified on this Improvement Permit.

Signed _____ 200

(IMPROVEMENT PERMIT IS VALID F 60 MONTHS FROM DATE OF ISSU

Pump specs: 28 gal/min at Approx 26' head. Dose volume 200 gal/7 min c

IMPROVEMENT PERMIT BY David R. Hinson, RS DATE _____

COMMENTS All nitrification trenches to follow contour; Trench bottom depth to be NO deeper than 18" (6" natural cover) from existing grade; Pump tank to be water tight. * Septic Tank contractor to have conference with Health Dept. prior to installing sy * septic installation

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold