DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2F6A45
PROPERTY RECORDED: Y/S
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Chris Penas OWNER: AGENT: PHONE: 563-9518
ADDRESS: 7435 Parmgate Dr. APPLICATION DATE: DATE EVALUATED: 7/12/93
Charlotte 28215 PROPOSED FACILITY: 3 Bedroom SF Dwelling
PROPERTY SIZE: 80' x 200' -
LOCATION OF SITE: Lot 45, Holiday Harbor
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-2"	gr. l/scl	1:1 vfr	-	-	PS	-	.5
		2-30"	sbk/c	1:1 fi	-	-	PS	-	.35
		30-42"+	wbk/sicl	1:1 fr	-	-	PS	-	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .3-.35 gal/sf/day
EVALUATED BY: OTHER(S) PRESENT:
COMMENTS: