4626442214

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Thomas DATE 7-10-79 PERMIT NO. 235

PHONE: Business _____ Home _____


LOCATION 1100 Tl on 1115 Tl past Church on Private Rd. ~½ mi Tl on Dead end rd at end S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 58 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 mpi	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+	
Lot Area ½ Ac +			Rock or other impervious formations	none obs.	



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by Leon Thompson

IMPROVEMENTS PERMIT BY W R Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 7-10-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold