2800

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Thomas DATE 6-15-79 PERMIT NO. 187

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1115 past Church TL on private road ~½ mi. TL on Dead end road at end S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 58 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ½ Ac. +

Character & Porosity of Soil Clay loam
Percolation Rate 80 mpi
Topography 2%
Depth to Water Table 4' +
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10" +
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: Sewage system to be installed before house is built. Critical to keep system as shallow as possible. Keep tank out of ground and mound over it w/ excess dirt. Drain line not to have more than 18" cover (12-18" preferably)

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold