IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Floyd merritt DATE 9-27-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1115 Turn left at Church [illegible] .6mi turn left at end of Road S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 57 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Existing
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	System

Lot Area 3/4 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Orbison
1966

IMPROVEMENTS PERMIT BY _____

COMMENTS: System is adequate for house
Pull trailer off property after house
is ready for use.

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 9-27-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold