PARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
VISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Renee Osborne
ADDRESS: 389 Agnew Rd
PROPOSED FACILITY: SFD
PROPOSED DESIGN FLOW (.1949): 480gpd
LOCATION OF SITE: 389 Agnew Rd Cl Lot 8 Lot #67
APPLICATION DATE
DATE EVALUATED: 6/30/14
PROPERTY SIZE: _____
PROPERTY RECORDED: _____

WATER SUPPLY: [X] Private [ ] Public [ ] Well [ ] Spring [ ] Other _____
EVALUATION METHOD: [X] Auger Boring [ ] Pit [ ] Cut
TYPE OF WASTEWATER: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8% to 10%	0-3	Top Soil						.25
		3-11"	Rd/Brn Hogel	Brn C/CL m-wSBK					
		11-38"	Yell/Brn CL	w/ few to many SAP Incls					
		38-48	Yell/Brn LS	SAP w/ Incls of CL & W. Rock					
2	L 7% to 10%	0-3	Top Soil						.25
		3-12"	Rd/Brn C/CL						
		12-36"	Yell/Brn C	few to many SAP Incls					
		36"-48	Yell/Brn LS	SAP w/ Incls of W. Rock					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II & III	IV
Site LTAR	.25	.25

OTHER FACTORS (.1946): None
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: M. Dotson
OTHER(S) PRESENT: _____

COMMENTS: _____