4626 460 460

09273

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Timothy M. Knox DATE Dec 2, 88 PERMIT NO. 20-B

PHONE: Business _____ Home _____

LOCATION 1100 TR 1115 TR 1445 (Kerr) TR 1257 (Agnew)

S. R. No. _____

SUBDIVISION NAME Clt Lake Norman LOT NO. 78 SECTION OR BLOCK NO. 8

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes (✓) No ( )

Character & Porosity of Soil clay

Percolation Rate 2, 35


Topography 2-6%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

Lot Area 20000 SF+ LAKE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by A.G. Evans

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY AEP

COMMENTS: [redacted]

CERTIFICATE OF COMPLETION BY D R Harrison, RS DATE 12/2/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

09273

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Timothy Mack Knox DATE 11/18/88 PERMIT NO. 208

PHONE: Business _____ Home 892-8713

LOCATION 1100 TR McKendrie TL Kemp TL Agnew On R. S. R. No. 1257

SUBDIVISION NAME Section 8 Cland T LOT NO. 78 SECTION OR BLOCK NO. ZF-3-A-78

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clayey
Percolation Rate 35
Topography 6-10%
Depth to Water Table 41+
Rock or other impervious formations none observed

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Timothy Knox and Kathy

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: Install tank and lines shallow. Lines are to be level and no deeper than 30". Initial system must be uphill high enough to reserve 100% repair by gravity on below.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold