## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Cardner DATE 9-13-79 PERMIT NO. 316

PHONE: Business _____ Home _____

LOCATION 1100 TRon 1115 TLon 1445 TLon 1257 1000' on Rt. S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 77 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )
Lot Area 1.77AC.

Character & Porosity of Soil Clay Loam
Percolation Rate 50 mpi
Topography 4-8%
Depth to Water Table 4.5'
Rock or other impervious formations none obs.




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 100 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Leon Thompson

IMPROVEMENTS PERMIT BY J.C. Moore ; Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 9-13-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Gardner DATE 8/14/79 PERMIT NO. 242

PHONE: Business _____ Home _____


LOCATION Rd 1400 TR 1115 [illegible] TL 1445 (1.25 mi) TL 1247 [illegible] 1000' on R S. R. No. 1247

SUBDIVISION NAME Lake Norman LOT NO. 77 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms _____

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (X) | Character & Porosity of Soil | parent material |
| Auto. Dishwasher | Yes ( ) | No (X) | Percolation Rate | 80 mpi |
| Auto. Wash. Machine | Yes ( ) | No (X) | Topography | 4-8 % |
| Site Suitable | Yes (X) | No ( ) | Depth to Water Table | 4.5' |
| Lot Area .77 ACRE | | | Rock or other impervious formations | NONE OBSERVED |




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16" +
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY J.C. Moore + Fred Clemmer

COMMENTS: Divert surface $H_2O$ and roof drains piped away from area of Nitrification Line + septic tank

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold