DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms
ADDRESS: ___
APPLICANT: ___
APPLICATION DATE: ___
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 480 gpd
DATE EVALUATED: 2-8-05
LOCATION OF SITE: Lot 389 The Farms
PROPERTY SIZE: ___
PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	gr wk sbk fr ss sp	fr ss sp	few ind yp w. rock fr sap				.25
		4-34	wk fsbk rcl	fr ss sp sx p					
		34-48	wk fsbk-massive L sap	fr ss sp	common ind yp w. rock fr sap				
2		0-5	wk sbk scl	fr ss sp	few ind w. rock				.3
		5-34	wk sbk rc	fr ss sp					
		34-54	wk sbk cl	fr ss sp	few-common ind sap w. rock				
3	11-12% L	0-5	wk sbk-fr sc scl	fr ss sp					.3
		5-30	wk fsbk rc	fr ss sp					
		30-50	wk f gr cl	fr ss sp	few ind sap				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 25% Red	LPP BPS
Site LTAR	.3	.125-.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT: ___