DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms LLC APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 2-8-05
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 392 The Farms PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-5	wk sbk lbr sdl	fr sss p					.25
		5-28	m sbk rc	fr ss-sss p sep					
		28-52	wk sbk rd cl	fr sss p	common - many red yel mott				
2		0-4	wk sbk scl	fr sss p					.3
		4-29	m sbk rc	fr sss p					
		29-48	wk sbk yel cl	fr sss p	few fine red mott				
3	5% X 5% S	0-6	wk sbk lms cl	fr sss p					.3
		6-21	m sbk rc	fr sss p					
		21-54	wk sbk yel cl	fr sss p	few fine mott				
4		0-6	wk sbk scl	fr sss p					.3
		6-32	m sbk rc	fr sss p sep					
		32-54	massive c sap	fr ss p					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	6"±1 25% Red	pumped 25% Red
Site LTAR	.3	.25-.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DP Hennessy
OTHER(S) PRESENT: Paul Pennington