3:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# ~~13965~~ 20191 PIN# 4626-48-6801.000 DATE March 12, 07

OWNER OR APPLICANT The Farms LLC PHONE: Business _____ Home _____

ADDRESS 1160 Wagner St. Taylorsville N.C. 28681

LOCATION Brawley School Rd TR McKendree TR Bush TR Montclair TR Silver Lake on Right

SUBDIVISION The Farms BLOCK / SECTION 5 LOT 553 LOT AREA .93Ac SITE CLASS. PS DESIGN FLOW 460gpd L.T.A.R. .025

Septic Tank: 1500 ✱ Gallons; STB 378 Date 6-9-14
Pump Tank: 1500 ✱ Gallons; PT 477 Date 5-27-14
Pump Make: Gould Model WE0572HHP Serial No. _____
Nitrification Field: No Fields 1 Square Feet 640 Linear Feet 320
No Lines 4 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LPPBPS
Repair System Description: LPPBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons _____
☐ Business No. Employees _____
☐ Other _____

Water Supply: ☐ Individual ☒ Public ☒ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: ✱ Per plan specs
Set 3ft. pressure 8/13/14
Checked Electric alarm
103' from Patio to Supply line

Comments:/Conditions:
55'
82
95'
90°

INITIAL SITE SKETCH

SEE PLAN from S&ME

AS BUILT SKETCH

Checked Lines 7-14-14
+ Supply Line AEA
Line Lengths 55'; 78, 96, 95'
Checked ST & PT 7/15/14 MK

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with ~~plat~~ valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 4-30-07 Installed by: Gary Leatherman

Improvement Permit by: _____ date 3-12-07 Operation Permit by: _____ date 8/13/14

Authorization to Construct by: _____ date 3-13-14 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK