DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Lee Easton APPLICANT:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 1-10-96
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
LOCATION OF SITE: Lot 1 Hawks Nest PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

Now Lot 6

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	Eroded LSS ~10%	0-8	gr. loam sCL	1:1 fr					
		8-18	SAB RC	1:1 fi, sp					
		18-48	SAB RCL	1:1 fi-fr	sp				3
			gray mottles beginning @ 34"						
2	LSS ~10% and SL + wavy	0-7	gr. loam sCL	fr					
		7-26	SAB RC	1:1 fi sp					
		26-48	SAB - RCL	1:1 fr-fi sp					
			22"+ common yellow mottles						
3	LSS	0-10	gr. sCL	fr 1:1					
		10-22	SAB RC	fi sp					
		22-49	mod R RCB	fi-fr to sp					
			lithorelicts @ 49"						
			common yellow mottles 22"						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT:

2@90
12.5