4626499803

IREDELL COUNTY HEALTH DEPARTMENT

15360

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Richard & Carol Luttrell DATE Feb 10, '93 PERMIT NO. 212A402

PHONE: Business _____ Home _____

LOCATION 1100 TR 1115 TR 1457 (Bright Cir.) TR 1st street TL next street on right at end S.R. No. _____

SUBDIVISION NAME Crescent / Lake Norman LOT NO. 402 SECTION OR BLOCK NO. 8

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit Yes ☑ No ☐

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 1.39 Ac.

Soil Characteristics ps clay


Application Rate .3 gal/ft²/day

Topography 4 to 8%

Depth to Water Table > 4'

Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. _____ Linear Ft. 280' of

Depth of Stone in Lines 16" PABS

Water Supply: Individual ☑

Public ☐

Installed by Richard Abernathy

I understand and agree to install a septic tank system as specified on this Improvement Permit.

The proposed / existing 25'x28' GARAGE w/ BASEMENT addition does not appear to impact the existing septic system.

**NOTE: Keep Building 25' or greater from well

Chris E. Pratt R.S.

Date: _____

ICHD-Environmental Health Division

IMPROVEMENT PERMIT BY _____ DRH

COMMENTS NEW GARAGE Tank & drainfield checked by DRHamrick

D-box & hookups Checked by Wesley Sparks.

Old well abandonment checked by DRHamrick

@ New Wellsite

Operation permit

CERTIFICATE OF COMPLETION BY Jack R. Hamrick, RS DATE 2/10/'93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold