DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Saussy Burbank OWNER:__AGENT:__ PHONE:_____
ADDRESS:_____APPLICATION DATE:_____DATE EVALUATED:_____
_____PROPOSED FACILITY:_____
_____PROPERTY SIZE:_____
LOCATION OF SITE: lot 58, The Harbour
WATER SUPPLY: On-Site Well____Comm. Well___Public___Other_____EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-9	gr-scl	1:1 vfr					.4
		9-24	SBKb-c	1:1 fi					
			Stopped @ 24"						
			hit rock						
2		0-8	gr-scl						.4
		8-38	SBKb-c						.3-.3
		38-44+	mssl-cl						
3									
4									
5									

AVAILABLE SPACE (.1945) U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DWilliamson OTHER(S) PRESENT: Jeff Coombs
COMMENTS: Site can be reclassified PS per rule '1956 provided adequate separation