4626520317

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rosemary James DATE 3-7-80 PERMIT NO. 39

PHONE: Business _____ Home _____

LOCATION 100 Ron 1177 Ron 1279 T.L. on 1280 ½ mi on Rt S. R. No. _____


SUBDIVISION NAME Holiday Harbor LOT NO. 27 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 2½ AC.

Character & Porosity of Soil clay loam
Percolation Rate 5 Empi
Topography 15% +
Depth to Water Table 6' +
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16-20"
Water Supply: Individual (✓)
Public ( )

Installed by J.J. Ervin

IMPROVEMENTS PERMIT BY [illegible]

COMMENTS: Drainfield between 75 & 80 feet in length, but worked out at end to get footage because of closeness to property line.

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 3-7-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold