4626-52-3195

IREDELL COUNTY HEALTH DEPARTMENT

11510

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Weisswanger DATE June 21, '90 PERMIT NO. 2F-6-A-111

PHONE: Business _____ Home _____

LOCATION 400 TR 1177 (Chickwood) TR Seagrove (1279) to end Bear left at end on right S. R. No. _____

SUBDIVISION NAME Holiday Harbor LOT NO. 14 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Addition (20'x30')
w/ Addn

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes ( ) No ( )
Lot Area Existing

Character & Porosity of Soil PS clay
Percolation Rate 2-4
Topography ~6%-10%
Depth to Water Table 6'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field: 4 panels 5 lines
No. of Lines + Bed Addn.
Sq. Ft. _____ Linear Ft. 158' ±
Depth of Stone in Lines 16" Top
Water Supply: Individual (✓) panels
Public ( )

Installed by Dwight Wooten

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE June 21

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

rmit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making rovements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold