IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Griffis DATE 4-16-76 PERMIT NO. 90

PHONE: Business _____ Home 464-2311

LOCATION 1100 Flow 422 turn left at 1st lane on right

SUBDIVISION NAME Lake Norman LOT NO. 10 SECTION OR BLOCK NO. 6 S. R. No. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 4 acre

Character & Porosity of Soil Clay loam Porous
Percolation Rate Not Taken
Topography Fair Slope
Depth to Water Table 10 Ft
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Williams Septic Tank

IMPROVEMENTS PERMIT BY John Hamilton

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hamilton DATE 4-16-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold