IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jan A Long DATE 2-16-78 PERMIT NO. 22

PHONE: Business 847-6911 Home

LOCATION 1100 TR on 1222 Bare Lift 1st on right

SUBDIVISION NAME Lake Norman LOT NO. 8 SECTION OR BLOCK NO. 8 S. R. No.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1.30 ac


Character & Porosity of Soil Clay loam

Percolation Rate 60 mn/in

Topography 2 2% 5% ac

Depth to Water Table 6' to 8'

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 18"

Water Supply: Individual (✓)

Public ( )

Installed by Bruce Lack

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 2-11-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold