IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eddie Hoffman Jr. DATE 6-7-79 PERMIT NO. 196

PHONE: Business _____ Home _____


LOCATION 1100 TR on 1222 bear to Rt at forks (1257) ¼ mi on left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 29 SECTION OR BLOCK NO. 8

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	25-30%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk.	
Lot Area ¾ AC.			Rock or other impervious formations	none obs.	



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"+
Water Supply: Individual (✓)
Public ( )

Installed by F J Erwin

IMPROVEMENTS PERMIT BY David R Hanson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hanson DATE 6-7-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold