IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Crighton DATE 5-3-05 PERMIT NO. 75

PHONE: Business _____ Home _____

LOCATION 1000 Rd pvt 1232 right off of Hwy 64 E Left

_____ S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 30 SECTION OR BLOCK NO. 8

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(X)	
Auto. Dishwasher	Yes	(X)	No	( )	
Auto. Wash. Machine	Yes	(X)	No	( )	
Site Suitable	Yes	(X)	No	( )	

Lot Area 1 Acre


Character & Porosity of Soil Sandy Clay

Percolation Rate 30 MPI

Topography Slopes

Depth to Water Table 10 Ft

Rock or other impervious formations Sandy Clay



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 24"

Water Supply: Individual (X)

Public ( )

Installed by Ken Kimbrell

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic tank to be pulled over 100'

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold